

CONTROL 4DOF TELE-OPERATION MANIPULATOR

Tu Diep Cong Thanh

University of Technology, VNU-HCM

(Manuscript Received on April 5th, 2012, Manuscript Revised May 30th, 2013)

ABSTRACT: *Tele-operation manipulator (TM) is well-known as the best solution for interacting between humans and the unsafe environment such as dangerous, toxic, infectious or sterile. In this study, a low cost TM system is introduced. In addition, the network control algorithms to overcome teleoperation are proposed.*

KEYWORDS: *Tela-operation, Control, LAN*

1. INTRODUCTION

Tele-Operation Manipulator (TM) system is a remote control manipulator consists of two arms: the master and slave. Slave manipulator will be controlled to perform the same motion as master manipulator. To implement this control, master manipulator will be controlled by human. The desired motion of the master manipulator will be recognized by sensors and these values will be transmitted via LAN to the slave manipulator controller.

In 1898, Nikola Tesla made boat control model using radio in New York first to now, the TM has a history of development over a century [1]. TM system as the first true master - slave is made a pure mechanical structure is benevolent R. Goertz late in 1940 at the National Laboratory Argonne [2]. In 1954, Goertz's team developed the first electro mechanical manipulator with feedback servo control. With the development of more modern techniques, the TM system appear in many areas more efficient service to people such as

explosives detection arm of national defense and arm on the spacecraft, the main in space [3], hand-picking machine of nuclear fuel in nuclear power industry, the submersible manipulator on the seabed studies [4], and especially the type of arm surgery in remote health [5].

One of the outstanding research of robots for medical applications such as manipulator system for remote microsurgery institute KAIST, Korea [6] and surgical manipulator system accuracy in medicine at the University of Washington , USA [7]. TM control to execute as well as the ability to monitor and respond in real time, a number of studies related to model algorithms and system control are presented, such as adaptive control using a control algorithm slide is presented by Plato [8], techniques to reduce transmission time over the network in control TM was suggested by Lee [9], Sano technical proposal in the time delay compensation control TM [10], with Towhidkhah modeling and predictive control

[11], and robust control with random time delay proposed by Prokopiou [12], etc..

In this study, a low cost TM system which is attended to apply to healthcare service is presented. Regarding to healthcare service, the TM system should be respected to low cost with acceptable error and strong robustness without regard to external environments and reference inputs. For the purpose, a PID controller as well as network control algorithm are applied to control TM system with four degrees of freedom (4DOF) via LAN. Results obtained will be presented through experiment.

2. EXPERIMENTAL SETUP

The overview of system and schematic diagram of system are presented in figure 1 and figure 2 respectively.




Fig 1. Overview of the proposed TM system




Fig 2. Schematic diagram of system

The system includes master manipulator is controlled by human and enforce slave manipulator motion the same with the master manipulator motion. Parameters of motion of the master manipulator are recognized by the encoders (USDigital S5 Optical 1024R/P) and sent to PC server (computer 2.4 Ghz Pentium IV) through PCI 1784 circuit. PC server transmits these informations to the PC client via LAN (computer Pentium IV 2.4 Ghz) as well as getting back the response of 4 DOF TM. To control slave manipulator, PC server will compute the control signals and sent these signals to low cost circuit using micro-controller PIC 18F4450 through PC client via LAN. Control software is coded based on C#, and the photograph of experimental system is shown in figure 3.



Fig 3. Photograph of the experimental apparatus

3. CONTROL SYSTEM

3.1. The overall of control system

The overall of control system is shown in figure 4. The system will include control algorithms on the PC server, PC client, the algorithm for control circuit using PIC 18F4450 and PIC 18F4431.




Fig 4. The overall of control system

3.2. Control algorithm on the PC server

The flowchart of PC server is presented in figure

When the program started, the PC server will send the requested connection to the PC Client and wait for connect. When two computers are connected, the PC server will perform the work as follows:

- Check the start point of master manipulator
- Read the encoder values of the joint angles
- Send these values to PC Client via LAN
- Wait to receive signal response of the slave manipulator




Fig 5. The flowchart of PC server

- To display the results of control on charts
- Compute the controller
- Send control signal to PC Client
- To repeat the program until receiving the stop signal




Fig 6. The flowchart of PC Client

3.3. Control algorithm on the PC Client

The flowchart of PC Client is presented in figure 6. When the program started, the PC Client will send the requested connection to the PC server and wait for connect. When two computers are connected, the PC client will perform the work as follows:

- To start communication RS232 with motor control circuits - PIC Master 18F4450
- Send a requested-reset of slave manipulator
- Wait for the position feedback signal
- Send these values of encoders to PC server via LAN
- Get new angle signal from PC server
- Send control signal to PIC Master 18F4450
- Wait to receive feedback on the signal response
- To repeat the program until receiving the stop signal




Fig 7. The flowchart on the circuit PICMaster 18F4450

3.4. Algorithm for PIC Master 18F4450

The flowchart on the circuit PIC Master 18F4450 is shown in Figure 7. PIC Master 18F4450 will perform the work as follows:

- Created RS232 connection to PC Client
- Connect with I2C PIC Slave 18F4431
- Get the value of PWM pulses from PC

Client and transmitted to the Slave PIC18F4431

- Get encoder value from the PIC Slave 18F4431 and send to PC Client
- To repeat the program until receiving the stop

3.5 Algorithm for PIC Slave 18F4431

The flowchart on the circuit PIC Slave 18F4431 is shown in Figure 8. PIC Slave 18F4431 will perform the work as follows:

- Create the QEI module, PWM
- Get connected with I2C Master PIC18F4450
- Get the value of PWM pulses from the Master PIC18F4450
- Send encoder values to PIC Master 18F4450
- To repeat the program until receiving the stop signal




Fig 8 . The flowchart on the circuit PIC Slave 18F4431

3.6 PID Controller to Control Motor

The strategy of PID control has been one of the sophisticated methods and most frequently used in industry. This is because that the PID controller has a simple form and strong robustness in broad operating area. The structure of the PID control algorithm is shown in Fig. 9.




Fig 9. The structure of the PID control algorithm

The PID controller output can be expressed in the time domain as:

$$u_f(t) = K_p e(t) + \frac{K_p}{T_i} \int_0^t e(t) dt + K_p T_d \frac{de(t)}{dt} \quad (1)$$

Taking the Laplace transform of (1) yields:

$$U_f(s) = K_p E(s) + \frac{K_p}{T_i s} E(s) + K_p T_d s E(s) \quad (2)$$

The resulting PID controller transfer function of:

$$\frac{U_f(s)}{E(s)} = K_p \left(1 + \frac{1}{T_i s} + T_d s \right) \quad (3)$$

A typical real-time implementation at sampling sequence k can be expressed as:

$$u_f(k) = K_p e(k) + u_f(k-1) + \frac{K_p T}{T_i} e(k) + K_p T_d \frac{e(k) - e(k-1)}{T} \quad (4)$$

$$e(k) = y(k) - x(k) \quad (5)$$

where $u_f(k)$, $e(k)$, $y(k)$ and $x(k)$ are the output of conventional PID controller, the error between the desired set point and the output, the output and the desired set point, respectively.

The effectiveness of the proposed algorithm will be demonstrated through experiment.




Fig 12. Step response of PID Controller

4. EXPERIMENTAL RESULTS

At first, PID controller is applied for control the motion of slave manipulator. The control parameters of PID controller are chosen through trial and error. And there are $K_p = 1.5 \times 10^{-3}$, $K_i = 0.15 \times 10^{-3}$ and $K_d = 0.2 \times 10^{-3}$. The experimental result of step response of TM are shown in figure

12. From figure 12, it shows that response of system is stable. Time delay is happened due to the system response. Actually, time delay is sampling time which is set to control TM via LAN and it is 100 milliseconds. However, this is acceptable for low cost TM system which is applied to healthcare service.

In addition, from Fig. 12, with fast changes of joint angles, and performances with good tracking are also obtained with respect to step inputs. The errors are low and approximate of 2% of input amplitude.

In order to improvement control performance of system, triangle form and sinusoidal form are tested, and the experimental result is shown in figure 13 and figure 14 respectively. From experimental results, it is shown that the response of system with respect to PID controller is stable and good performance. Time delay is more happened with respect to sinusoidal form. It is because of the response of control system. The system is limited with the signal inputs which have the frequency is greater than 2Hz.

Finally, doing practice with movement of master manipulator and checking performance of slave manipulator. Experimental result is shown in figure 15. And it is no doubt that the TM system works well and the proposed algorithms are fine. The responses of slave manipulator are almost tracking with the reference input which is given from the motion of master manipulator.

The time delay is 100ms with respect to sampling time to control via LAN and the error

is acceptable which is approximation about 2% of amplitude of inputs.




Fig 13. Triangle response of PID Controller

5. CONCLUSIONS

In this paper, a low cost TM system as well as network control algorithms are proposed . It is shown that the proposed control methods had a good performance for tele-operation manipulator. It can be seen from experimental results that the controller had stable and strong robustness.




Fig 14. Sine response of PID Controller




Fig 15. Real response of TM system

This study also show out the flowchart for PC server, PC Client as well as flowchart of low cost circuit using microcontroller PIC 18F4450 and PIC 18F443.

From the experimental results, it shows that delay of response is given, and improvement control performance of system using intelligent control such as neural network or fuzzy logic will be applied in next study.

ĐIỀU KHIỂN HOẠT ĐỘNG TAY MÁY 4 BẬC TỪ XA

Từ Diệp Công Thành

Trường Đại học Bách Khoa, ĐHQG-HCM

TÓM TẮT: Tay máy hoạt động từ xa được biết đến như là giải pháp tốt nhất cho các tương tác giữa con người với các môi trường không an toàn như nguy hiểm, độc hại, cách ly và vô trùng. Trong nghiên cứu này, một hệ thống tay máy điều khiển từ xa giá thành thấp được trình bày. Thêm nữa, giải thuật điều khiển qua mạng được đề xuất để điều khiển từ xa.

Từ khóa: Hoạt động từ xa, điều khiển, LAN.

REFERENCES

- [1]. N. Tesla., Method of and Apparatus for Controlling Mechanism of Moving Vessels or Vehicles
<http://www.pbs.org/tesla/res/613809.html> (1898).
- [2]. Raymond Goertz, R. Thompson, Electronically Controlled Manipulator, *Nucleonics* (1954).
- [3]. A. K. Bejczy., Sensors, Controls, Man-Machine Interface for Advanced Teleoperation, *Science* (1980).
- [4]. R. D. Ballard., A last long look at Titanic, *National Geographic*, 170, 6 (1986).
- [5]. A. Bejczy, G. Bekey, R. Taylor, S. Rovetta, A Research Methodology for Tele- Surgery with Time Delays, *First Int. Sym. on Medical Robotics and Computer Assisted Surgery* (1994).
- [6]. Dong-Soo Kwon, Ki Young Woo, Se Kyong Song, Wan Soo Kim, Hyung Suck Cho, Microsurgical Telerobot system, *Intelligent Robots and Systems, Proceedings.*, 1998 IEEE/RSJ International Conference, (1998).
- [7]. Blake Hannaford, Diana Friedman, Hawkeye King, Mitch Lum, Jacob Rosen, Ganesh Sankaranarayanan, Evaluation of RAVEN Surgical Telerobot during the NASA Extreme Environment Mission Operations 12 Mission, Report of Dept of EE, University of Washington, (2009).

- [8]. Platon A. Prokopiou , Spyros G. Tzafestas, William S. Harwin, A Novel Scheme for Human-Friendly and Time-Delays Robust Neuropredictive Teleoperation, *Journal of Intelligent and Robotic Systems*, 25, 4, 311-340 (1999).
- [9]. Lee, S., Lee, H. S., Modeling, design and evaluation of advanced teleoperator control systems with short time delay, *IEEE Trans. Robotics Automat*, 9, 607-623 (1993).
- [10]. Sano, A., Fujimoto, H., Tanaka, M., Gain-scheduled compensation for time delay of bilateral teleoperation, *Proc. of IEEE Internat. Conf. on Robot. Automat.*, Leuven, Belgium, 1916-1923 (1998).
- [11]. Towhidkhah, F., Gander, R. E., Wood, H. C., Model predictive control: A model for joint movement, *J. Motor Behavior*, 29, 3, 209-222 (1997).
- [12]. Prokopiou, P. A., Harwin, W. S., Tzafestas, S. G., Variable-time-delays-robust telemanipulation through master state prediction, *AIM '99: 1999 IEEE/ASME Internat, Conf. on Advan. Intel. Mechatronics*, Atlanta, USA, 19-22 (1999).